



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Newark Educators Community CS., 12 Fulton Street, Newark, NJ 07103
PAS Project ID : P24-06782

Matrix : Drinking Water
Report Date : 7/19/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-06782-01	NECCS-1-BF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 07:32	7/12/24 10:14
P24-06782-02	NECCS-1-S-01A	Lead	12.5	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 07:35	7/12/24 10:26
P24-06782-03	NECCS-2-B-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 07:53	7/12/24 10:30
P24-06782-04	NECCS-2-B-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 07:55	7/12/24 10:34
P24-06782-05	NECCS-2-BF-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 07:59	7/12/24 10:39
P24-06782-06	NECCS-2-B-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 08:02	7/12/24 10:43
P24-06782-07	NECCS-2-B-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 08:04	7/12/24 10:47
P24-06782-08	NECCS-3-B-05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 08:13	7/12/24 10:51
P24-06782-09	NECCS-3-B-06A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 08:15	7/12/24 10:55
P24-06782-10	NECCS-3-B-07A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 08:18	7/12/24 10:59
P24-06782-11	NECCS-3-B-08A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 08:20	7/12/24 11:25
P24-06782-12	NECCS-3-S-02A	Lead	2.45	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 08:28	7/12/24 11:41
P24-06782-13	NECCS-3-BF-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 08:31	7/12/24 11:45
P24-06782-14	NECCS-4-BF-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 08:37	7/12/24 11:49
P24-06782-15	NECCS-FB	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/2/24 07:30	7/12/24 12:01

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer